

number 93835/02 Replaces 93835/01
Date of issue 11-12-2017 Issued first 23-11-2016
Report number 161000141

Declaration regarding the efficiency of a shower heat recovery unit

DECLARATION OF KIWA

This declaration is based on a single examination by Kiwa on a product supplied by

Q-Blue B.V.

This declaration does not pass a judgment on other products supplied by the manufacturer.


The product was tested according the procedure according annex B of the NEN7120:2011/C2:2011.

PRODUCT NAME

Showersave®-QB1-21

class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance (ΔP) (bar)
3	9.2	73	65.0	0.30
4, 5, 6	12.5	100	61.4	0.52

Allard Slomp
Productmanager



Kiwa Nederland B.V.

Kiwa Nederland B.V.
Wilmsdorp 50
Postbus 137
7300 AC Apeldoorn
Tel. 088 998 33 55
Fax 088 998 36 85
E-mail eup@kiwa.nl
www.kiwa-eup.nl

Q-Blue B.V.
Willem Barentszstraat 5
7825 VZ EMMEN
The Netherlands
+31 (0) 591 374570
info@q-blue.nl
www.q-blue.nl

